



TEST CERTIFICATE

CLIENT	Raleigh Adhesive Coatings Ltd. Raleigh Hall Industrial Estate ECCLESHALL Staffordshire ST21 6JL
SITE	DRY CLEAN ROOM
AIR QUALITY	BS EN ISO 14644-1 Class 7 @ 0.5µm level.
RATE OF AIR CHANGE	13.60 Air changes per hour
DIFFERENTIAL PRESSURE	10Pa (Relative to exterior via transfer)
SITE	WET CLEAN ROOM
AIR QUALITY	BS EN ISO 14644-1 Class 7 @ 0.5µm level.
RATE OF AIR CHANGE	25.40 Air changes per hour
DIFFERENTIAL PRESSURE	3Pa (Relative to exterior via transfer)
TEST DATE	9 MARCH 2009
ISSUE DATE	27 MARCH 2009


C. JOHNSON
SENIOR TECHNICIAN

